



## Transmission Services

---

### Montana Intertie/Broadview-Garrison

Updated: 06/02/2010

Transmission Services posts Available Transmission Capacity (ATC) for its portion of the Montana Intertie (MI\_E>W)(also known as Broadview to Garrison) transmission path on its OASIS. Outages and other operational constraints involving the MI\_E>W Flowgate are reflected in the Operational Transfer Capability (OTC) values for the Montana to PNW Flowgate.

For information about the OTC implications of Broadview-Garrison outages, refer the MPC-NW section on the [Outages and Interruptions page](#) on the Transmission Services web site. Information about proposed outages is available West of Garrison section of the Northwest Power Pool 45-day outage process spreadsheets posted on the [Proposed Outages](#) web page.

The Broadview to Garrison path is comprised of two lines:

Broadview - Garrison #1 500kV

Broadview - Garrison #2 500kV

This path is limited in the east to west direction. BPAT does not have west to east transmission rights on the Montana Intertie (Broadview-Garrison 500kV lines). Consequently ATC is computed and tracked only in the east to west direction for this path.

To request service over this path specify Broadview 500kV/Broadview as the Source/POR and Garrison 500kV/Garrison as the Sink/POD.

Point to Point service over BPAT's share of the Broadview-Garrison 500kV lines is provided at the Montana Intertie Rate. Refer to the current [Transmission and Ancillary Service Rate Schedules](#) for rate information.

Service over this path goes to only the Garrison 500kV bus. Since load or non-BPAT transmission is not available at the Garrison 500kV bus, customers who take service over BPAT's share of the Broadview-Garrison 500kV lines must also obtain either firm or non-firm Point to Point transmission service on TBL's Network System.

If you have questions, please contact your Account Executive or the Transmission Services Reservation Desk at (360) 418-8499.