



## Tagging Provisions for Transactions through Hot Springs, Version 1 - Bulletin

Effective: 06/01/09

Associated business practice: Scheduling Transmission Service

Avista, BPA, Idaho Power, NorthWestern Energy, and PacifiCorp have worked together on managing the capacity across the West of Garrison path, including the Hot Springs Substation. The result is the implementation of capacity management procedures associated with the Hot Springs POR<sup>1</sup>/POD<sup>2</sup>, the Amps Line, and the Montana-to-Northwest Path. These are described in the Attachments and detailed in the tagging examples.

---

<sup>1</sup>Point of Receipt is an interconnection on the Transmission Provider's Transmission System where capacity and energy will be made available by the Delivering Party; An OASIS field on a TSR that is the scheduling POR.

<sup>2</sup>Point of Delivery is a point on the The Transmission Provider's Transmission System where capacity and energy transmitted by the Provider will be made available to the Receiving Party; An OASIS field on a TSR that is the scheduling POD.

## New Tagging Provisions

1. Tag authors must adjust their templates to use the structure identified in the tagging examples below. This tagging protocol must be used for tags submitted on or after June 1, 2009 for flow on or after June 2, 2009.
2. The interim tagging paths HTSP.AVA to HTSP or HTSP to HTSP.AVA (using a SERVICENOR contract designation) will no longer be used. Tag authors must use BPAT.NWMT for Hot Springs deliveries when transactions flow to/from the BPAT Balancing Authority Area, for transactions flowing to/from the Avista Balancing Authority Area, tag authors will use a newly registered point, AVA.NWMT.
3. The following are some "generic" tagging examples using the Post-Interim (Final) Hot Springs Solution. These examples show flow from, to, and/or through the BPAT Balancing Authority Area. For transactions that flow to/from/through the Avista Balancing Authority Area. Postings for similar tagging examples are provided on Avista's, Northwestern Energy's, and PacifiCorp's websites.
4. For questions about tagging the BPAT segments call the BPA Transmission Services Real-Time desk at (360) 418-2878.

## Examples

### Tagging Example - West to East

**Note:** The OATI<sup>1</sup> system screenshots included in this document are proprietary and not to be used outside the context of this document. Do not distribute without specific authorization from OATI.

| Physical Path |           |        |           |           |      |                       |
|---------------|-----------|--------|-----------|-----------|------|-----------------------|
| CA            | TP        | PSE    | POR       | POD       | SE   | Contract              |
|               | BPAT      | "----" | "----"    | BPAT.NWMT | BPAT | BPAT TSR <sup>2</sup> |
|               | <AMPS TP> | "----" | BPAT.NWMT | BRDY      | NWMT | "---"                 |
|               | <AMPS TP> | "----" | BPAT.NWMT | BRDY      | PACE | "---"                 |
|               | <AMPS TP> | "----" | BPAT.NWMT | BRDY      | IPCO | "---"                 |

<sup>1</sup>Open Access Technology International System

<sup>2</sup>Transmission Service Request

**Tagging Example - East to West**

| Physical Path |           |       |           |           |       |          |
|---------------|-----------|-------|-----------|-----------|-------|----------|
| CA            | TP        | PSE   | POR       | POD       | SE    | Contract |
|               | "----     | "---- | "----     | BRDY      | "---- | "--"     |
|               | <AMPS TP> | "---- | BRDY      | BPAT.NWMT | IPCO  | "--"     |
|               | <AMPS TP> | "---- | BRDY      | BPAT.NWMT | PACE  | "--"     |
|               | <AMPS TP> | "---- | BRDY      | BPAT.NWMT | NWMT  | "--"     |
|               | BPAT      | "---- | BPAT.NWMT | "----     | BPAT  | BPAT TSR |

**Attachments**

Attachment 1: Capacity Management Procedures Frequently Asked Questions

Attachment 2: Capacity Management Procedures Agreement